

**Statement of Work
for
Intrusion Alarm System Maintenance**

January 12, 2010

Table of Contents

1	INTRODUCTION.....	1
1.1	BACKGROUND	1
1.2	CUSTOMER.....	1
2	REQUIREMENTS	1
2.1	TEST AND VALIDATE OPERATION	1
2.2	TEST AND REPLACE BATTERIES	1
2.3	SYNCHRONIZE ALARM DEVICES	2
2.4	COST ESTIMATE FOR REPAIR	2
2.5	DOCUMENTATION	2

1 INTRODUCTION

1.1 BACKGROUND

The purpose of this statement of work is to test and document the intrusion detection system (IDS) at the Dryden Flight Research Center (DFRC) on Edwards Air Force Base, California that consist of twenty-eight (28) Bosch D 7212 alarm panels with D1260 Bosch Keypads and the two hundred thirty-nine (239) alarm points. The current Bosch IDS is interfaced with the Lenel OnGuard Pro software, and programming of the Bosch panels is performed by the Bosch Remote Programming Software (RPS).

1.2 CUSTOMER

The customer for this project is the DFRC Office of Protective Services.

2 INSTRUCTIONS

2.1 SITE SURVEY

A site survey will be offered to vendors wishing to bid on this statement of work. During this site survey, the bidders will be shown the location of all the alarm panels and each device attached. Anyone wishing to bid must attend the site survey. A date will be provided for the survey along with instructions to submit personnel wishing to attend there will be a limit of two representatives per vendor.

2.2 DFRC FAMILIARITY

The vendor shall have prior knowledge of DFRC infrastructure and Bosch IDS.

2.3 PRICING AND PERIOD OF PERFORMANCE

Each requirement shall be separately priced as an option. The period of performance (POP) for this project shall not exceed 90 days from the date of contract award.

3 REQUIREMENTS

3.1 TEST AND VALIDATE OPERATION

The vendor shall test and validate the operation of all intrusion alarm panels, their connected alarm devices and keypads. The vendor shall be given access to the Lenel OnGuard Pro software, the Bosch (RPS) and the Bosch keypads for this purpose.

3.2 TEST AND REPLACE BATTERIES

The vendor shall test and validate operation of 12 Volt DC battery backup of each alarm panel. The vendor shall replace any defective batteries or batteries

older than three years in service. The vendor shall be given access to the Lenel OnGuard Pro software, the Bosch (RPS) and the Bosch keypads for this purpose. NASA shall provide the vendor replacement batteries as required.

3.3 SYNCHRONIZE ALARM DEVICES

During the operational testing of IDS, the vendor shall correct and synchronize any device descriptions found in error on the Lenel OnGuard Pro software, the Bosch (RPS) and the Bosch keypads. Additionally, the vendor shall synchronize the time and date on the Lenel OnGuard Pro software and the Bosch panels via RPS, as necessary. The vendor shall be given access to the Lenel OnGuard Pro software, the Bosch (RPS) and the Bosch keypads for this purpose.

3.4 COST ESTIMATE FOR REPAIR

The vendor shall provide a cost estimate to repair any malfunctioning alarm devices or improperly installed alarm devices. The cost estimate shall be separately priced for each device to be repaired. Cost estimate should include all labor and materials necessary to repair. The customer, at their discretion, shall initiate a contract change request for the vendor to repair the alarm devices.

3.5 DOCUMENTATION

The vendor shall provide room/building drawing locations of alarm panels, keypads and connected alarm point devices. NASA will provide building/room blueprints of areas protected by the intrusion alarm system for this purpose.